

**Falls Township
Chimney Check List**

Owners Name:
Street Address:
City, State, Zip:

OK (is acceptable)

F (fail, not acceptable) any F's must be explained or repaired

N/A (does not apply)

Oil Flue Chimneys	Zero Clearance Fireplace
Proper size to NFPA 31 or Manufacturers Specification	Chimney meets NFPA 211, 2 ft, 3 ft, 10 ft rule
Chimney meets 2 ft, 3 ft, 10 ft rule	Clearance to combustible visible
Thimble Area clearance and condition	Hearth extension 6 sq or less 8" sides 16" front
No more than 2, 30 degree offsets	Hearth extension over 6 sq 12" sides 20" front
Condition of connector pipes and accessories	Clearance to mantle and trim
Crown wash and flashing	Appliance condition/masonry panels firebox
Listed cap for chimney system	Damper condition
Masonry chimney condition of flue liner	Cap and chase flashing
Class A chimney free from dents and buckling	Chimney free from dents/buckling/cleanliness
Clean out door or tree cap	Chase siding/stucco free warping
Clearance of connector pipes	Chimney has no more than 2, 30 degree offsets
Length of connector pipes	
Chimney cleanliness	
Gas B Vent	
Vent cleanliness	
Proper sizing to NFPA 54 or Manufacturers Specification	
Clearance of connector pipes	
Proper Manifold	
Condition of vent (free from rust & dents)	
Flashing from storm collar	
Vents meet heights as per NFPA 54	
Draft hood and damper	
Clean out tee	
Clearance to vent	

Comments:

Date of Inspection

Inspector:

Page 1 of 2