

<b>Falls Township Chimney Check List</b>	Owners Name:
	Street Address:
	City, State, Zip:

<i>OK (is acceptable)</i>	<i>F (fail, not acceptable) any F's must be explained or repaired</i>	<i>N/A (does not apply)</i>
---------------------------	---	-----------------------------

<b>Oil Flue Chimneys</b>	<b>Zero Clearance Fireplace</b>
Proper size to NFPA 31 or Manufacturers Specification	Chimney meets NFPA 211, 2 ft, 3 ft, 10 ft rule
Chimney meets 2 ft, 3 ft, 10 ft rule	Clearance to combustibles visible
Thimble Area clearance and condition	Hearth extension 6 sq or less 8" sides 16" front
No more than 2, 30 degree offsets	Hearth extension over 6 sq 12" sides 20" front
Condition of connector pipes and accessories	Clearance to mantle and trim
Crown wash and flashing	Appliance condition/masonry panels firebox
Listed cap for chimney system	Damper condition
Masonry chimney condition of flue liner	Cap and chase flashing
Class A chimney free from dents and buckling	Chimney free from dents/buckling/cleanliness
Clean out door or tree cap	Chase siding/stucco free warping
Clearance of connector pipes	Chimney has no more than 2, 30 degree offsets
Length of connector pipes	
Chimney cleanliness	
<b>Gas B Vent</b>	
Vent cleanliness	
Proper sizing to NFPA 54 or Manufacturers Specification	
Clearance of connector pipes	
Proper Manifold	
Condition of vent (free from rust & dents)	
Flashing from storm collar	
Vents meet heights as per NFPA 54	
Draft hood and damper	
Clean out tee	
Clearance to vent	

COMPANY NAME:	Pa. License # _____
COMPANY ADDRESS:	
COMPANY PHONE NO.:	
COMMENTS:	

Date of Inspection	Inspector:	Page 1 of 2
--------------------	------------	-------------

<b>Falls Township Chimney Check List</b>	Owners Name:
	Street Address:
	City, State, Zip:

<i>OK (is acceptable)</i>	<i>F (fail, not acceptable) any F's must be explained or repaired</i>	<i>N/A (does not apply)</i>
---------------------------	---	-----------------------------

<b>Masonry Fireplaces</b>	<b>Pellet / Wood/ Coal Stove Inserts</b>	
Hearth extension 6 sq or less 8" sides 6" front	Clearance plate on vent UL listed or to NFPA 211 standards	
Hearth extension over 6 sq 12" sides 20" front	Clearance and condition to connector pipes	
Proper spark arrestor	Condition of appliance	
Proper flue size and condition of flue liners	Proper thimble area clearance	
Proper smoke chamber size and condition	Proper wall or ceiling support class A chimney	
Chimney cleanliness	Chimney flue condition	
Condition of the crown	Proper spark arrestor	
Condition of the flashing	Chimney meets 2 ft, 3 ft, 10 ft rule	
Proper clearance to combustibles that are visible	Proper clearance of the appliance	
No more than 2, 30 degree offsets	Chimney connector accessories (barometric damper)	
Fire Box condition mortar joints	Proper hearth and back drop	
Condition of damper/top mount damper	Clean out tee on door	
Metal fire box grill openings	Class A chimney clearance to combustibles that are Visible	
Proper clearance to mantel & trim	Masonry chimney clearance that is visible	
If clean out door installed, condition of door	Direct connection to chimney flue	
Chimney meets 2 ft, 3 ft, 10 ft rule	Chimney cleanliness	
Lintel area filled with mortar	No more than 2, 30 degree offsets	
Natural gas logs, licensed plumber to check gas lines	Proper bracing of class A chimney	
Fireplace wood inserts direct connection to flue liners installed to manufacturers specification, or NFPA standards	Connector pipes same size off the branch of the unit 8" Units must have 8" chimney	
<b>Levittown Jubilee</b>		
Fire wall modification in place		

COMPANY NAME:	Pa. License # _____
COMPANY ADDRESS:	
COMPANY PHONE NO.:	
COMMENTS:	

Date of Inspection	Inspector:	Page 2 of 2
--------------------	------------	-------------